

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
PV 50526399

Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>	<i>(day/month/year)</i>
H.G.	01-SYM-CN217IYY 001	03.12.2021	

Genehmigungsinhaber *License Holder*
Gazioğlu Solar Enerji San.
ve Tic. A. Ş.
Gaziosman Paşa Mah.7.cd
No. 124 Çerkezköy
59500 Tekirdağ
Turkey

Fertigungsstätte *Manufacturing Plant*
Refer to latest revision
of the annex list of factories

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016
EN 61215-1:2016
EN 61215-1-1:2016
EN 61215-2:2017
EN IEC 61730-1:2018
EN IEC 61730-2:2018

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV Module

Type Designations:

Max. system voltage (Up to 1500VDC)

With half cut mono c-Si cells:

GSE-HCxxxMP (xxx=430-470, in steps of 5, 144 cells)

GSE-HCxxx (xxx=360-390, in steps of 5, 120 cells)

Remarks:

Class II acc. to IEC 61140

Fire Rating: Class C (according to UL 790)

Design Load / Safety Factors: 2400 Pa / 1.5 (downward)

1600 Pa / 1.5 (upward)

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

This certificate is valid until 01 December 2026.

*Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product
fulfills above mentioned requirements, the production is subject to surveillance.*

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

<http://www.tuv.com/safety> E-mail: markebeck@tuv.com

Fax: +49 221 806-3935

Zertifizierungsstelle



Dipl.-Ing. (FH) Tim Kirschner